



전기용품안전인증서

Electrical Appliances Safety Certificate

안전인증번호 : SW01001-2001A
(Certificate No.)

접수번호 : 05-1920-2955
(Order No.)

제조사명 : Feller GMBH.
(Manufacturer)

공장소재지 : Waerndorferstrasse 3 A-2525 Günselsdorf, Austria
(Factory Address)

제품명 : 코드류(범용폴리염화비닐시스코드) (PVC Sheathed Flexible Cables)
(Product)

기본모델명 : 60227IEC 53(H05VV-F), 3G 1.5mm²
(Basic Model)

정격 : AC300/500V
(Electrical Ratings)

파생모델명 : 60227 IEC 53 (H05VV-F),3G 1.0mm²,
(Series Model) 60227 IEC 53 (H05VV-F),3G 0.75mm²

적용기준 : K60227-5
(Applied Standard)

- 첨부 : 1. 기본모델·파생모델의 내용 (General Descriptions of Certified Products)
2. 전기용품안전인증서의 변경발급 현황 (Status of Compliance Certificate Revisions)

전기용품 안전관리법 제5조의 규정에 의하여 위의 전기용품에 대하여 안전인증서를 교부합니다.

We Certify Electrical Appliances Safety Certification as above product by Article 5 of the Electrical Appliance Safety Control Law.

2005년 09월 21일
year month day



안전인증기관
산업기술시험원

KOREA TESTING LABORATORY



첨부 1 : 기본모델·파생모델의 내용
General description of Certified Products

파생모델명 Derivative model	기본모델과의 차이점 Differences between the basic and derivative model(s)
60227 IEC 53 (H05VV-F), 3G 1.0 mm ²	Nominal sectional area
60227 IEC 53 (H05VV-F), 3G 0.75 mm ²	
제품특기사항 및 시험조건 Remarks & Test conditions	
<p>1. Test Report Ref. No. : 02-920-0899 (2002.03.26)</p> <p>2. Basic model, "60227 IEC 53 (H05VV-F) 3G 1.5 mm²" is - rated nominal sectional area is 1.5 mm², constructed with 3 wires with ground wire, external figure is the round circle type, sheathed with polyvinyl chloride</p> <p>3. permitted maximum using voltage between live and earth line & between live lines is AC300V/500V.</p> <p>4. "60227 IEC 53 (H05VV-F) cord" means "sheathed flexible power cable insulated with polyvinyl chloride" & the external sheath figure is round circle.</p>	
<p><input type="checkbox"/> 본 제품의 시험내용에 관하여 문의하실 사항이 있으시면 아래 연락처로 문의하시기 바랍니다. 시험담당자 : 전기전자본부, 신뢰성평가팀, 강호우 / (02)8601-415</p> <p><input type="checkbox"/> <i>If you have any question on product testing, please contact the person below :</i> <i>Job holder : Electro-technical Center Reliability Assessment Team, H.W.KANG/+82 2 8601-415</i></p>	

FP511-09-00

첨부 2 : 전기용품안전인증서의 변경발급현황
Status of Compliance Certificate Revisions

변경발급 내용 Contents of Certificate Revisions	비고 Remarks
<p>1st.Rev.) Basic Model, Derivative model, Electrical Ratings Change and Applied Standard Retest. (05-1920-2955 : 2005.09.13.)</p>	

FP511-11-00